

कयर बोर्ड / COIR BOARD
भारत सरकार / Government of India
सूक्ष्म, लघु और मध्यम उद्यम मंत्रालय / Ministry of MSME,
एम. जी . रोड , कोच्ची / M.G. Road, Kochi – 682016.

No. I-11011(11)/4/2016-ERS

Date : 15/03/2017

Addendum

Addendum to Tender Notification No. I-11011(11)/4/2016-ERS dated 23/02/2017 for supply and installation of UPS at the Coir Board HQ Kochi.16

The following clarification/modifications on the tender and the specification of the items to be supplied is prescribed. All the empanelled suppliers and prospective bidders may please take note of the same before submission of bids.

Sl.No	Activity	Action required
1	Redundancy required	hot standby
2	Battery rating	C-10 rating
3	Number of batteries	Each UPS battery pack may have upto 30 nos of battery
4	AH of battery	60 AH or higher
5	Output current (At full load)	80 KVA -347 Amp
6	Rectifier Type	SCR/IGBT with input power factor 0.9
7	Technology	MPWM, IGBT based inverter with input power factor 0.9
8	Wiring	The bidder has to ensure that wiring cables shall be copper wires and all materials using for wiring shall be a reputed brand with ISI/ISO standards.
9	Statutory body/authority approvals	Approvals, if any, required from statutory body/authority concerned have to be obtained by the bidder at their own cost.
10	Extension time limit for submission of tender	Last date and time for receipt of completed Tender : Till 14.30 hrs.on 05.04.2017 Date of opening of Tender Technical Bid (First stage) : 15.00 hrs. on 05.04.2017 Financial Bid (Price Bid) second stage : Will be informed at the time of opening of the technical bid

Kochi. 16
15.3.2017

Sd/-
Secretary
Coir Board.